

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1591:191 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: Edwards Systems Technology, 6411 Parkland Drive, Sarasota, FL 34243
Contact: Leon Newsome (941) 739-4276 Fax (941) 739-4334

DESIGN: Models 897B-002, -003, -007, -008, -009, -010, -102, -103, -107, -108, -109, -110, -111, and -112; 960A-8RF, -4RF, -4SS, -4SF, -8SS, and -8SF; 757A-SB, -SBW, -BDFW, -BDF, -RR2, -RR2W, -WB, -WBW, G1T, G1RT, G1T-FIRE, G1RT-FIRE back boxes and trim plates for signaling appliances. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as signaling appliance accessories for use with separately listed signaling appliances. For indoor use only except Models 897B-007, 897B-107, 757A-WB and 757A-WBW are also suitable for outdoor use. When use outdoor, the units are not suitable for the hearing impaired signaling appliances.

NOTE: Formerly 7300-1388:216

11-02-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 17, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager